T568B Termination Field Sheet

Reference guide for U.S. structured cabling to TIA/EIA-568-B standard

T568B Pin/Pair Color Code

Pin	Pair	Color
1	Pair 2	White/Orange
2	Pair 2	Orange
3	Pair 3	White/Green
4	Pair 1	Blue
5	Pair 1	White/Blue
6	Pair 3	Green
7	Pair 4	White/Brown
8	Pair 4	Brown

Field Termination Rules

- 1. Always use the same pinout (T568B) on both ends for straight-through cables.
- 2. Max horizontal cable length: 90 meters (295 ft).
- 3. Patch cords total length: 10 meters (33 ft) combined.
- 4. Maintain twist pairs up to 0.5 inches from termination.
- 5. Maintain proper bend radius: 4x cable diameter minimum.
- 6. Keep at least 12 inches separation from power cables.
- 7. Use Velcro ties, not zip ties, to avoid deforming the cable.
- 8. Label both ends according to TIA/EIA-606 standard.
- 9. Test each cable per ANSI/TIA-1152 field test procedures.
- 10. Follow TIA/EIA-569 for pathway and conduit requirements.